

5.14 UTILITY FAILURE: HVAC SYSTEM

Actions

- If animal room temperatures and humidity have fallen out of required range:
 - notify area supervisor to submit a Trouble Call with Facilities Management (310)825-9236 [available 24/7]
- If directional airflow is altered in a hazardous containment area:
 - immediately secure agents and/or animals
 - decontaminate work surfaces
 - exit facility normally
 - notify area supervisor and Biosafety Office (310) 206-3929